



**SERVOSAN®**  
**KURTARAN®**

## KU-S / 60VDCX - 3000VA

### KESİNTİSİZ GÜC KAYNAĞI KULLANIM KİLAVUZU

Yayın Tarihi : 11.01.2021  
Program No : 60VDCX\_CA

Sayfa Adedi : 4  
Revizyon No : 2

	Sayfa
1. İÇİNDEKİLER.....	1
2. TANITIM.....	1
3. ÖZELLİKLERİ.....	1
4. ÇALIŞMA ŞEKLİ.....	2
5. BUZZER VE LEDLER.....	3
6. UYARILAR, TEŞHİS VE GİDERİLMELERİ.....	3
7. PERYODİK BAKIM.....	3
8. GARANTİ.....	4
9. BLOK DİYAGRAM.....	4

#### 2. TANITIM:

1. Cihaz esas olarak **60V 7AH** akü ile çalışan **kesintisiz bir güç kaynağıdır**, 60V akü şarj devresi de içindedir.
2. Bu cihaz **tüm güçlerdeki inverterli** asansör panolarında, İnverterin **DC barasını** mevcut 60V aküden besleyerek, kata getirme için kullanılabilir.
3. Cihaz Ana Pano içine monte edilecek şekilde tasarlanmıştır, en 155mm, boy 228mm, yükseklik 210mm, ağırlığı 13.8 kg dır. Çalışma ortam sıcaklığı 0°C - 45°C dir.

#### 3. ÖZELLİKLERİ:

Cihazın standart bir UPS ye göre **fazladan özelliklerini** de vardır:

1. Cihaz **kata getirme işleminden kısa bir süre sonra STOP** eder ve bu andan sonra akülerden akım çekilmez, **aküler boşalmaz**. Cihaz AC gelince **tekrar canlanır**.
2. Cihazda **kesintisiz çıkış veren OUTL** çıkışından ayrı **gecikmeli çıkış veren K1 çıkışı** da vardır.

OUTL çıkışından elektrik kesintisinin olmaması gereken devreler ve cihazlar beslenir.

K1 çıkışından da zaman gecikmesi(20sn) ile beslenecek devreler beslenir.

3. Akü devresi üzerinde akülerin **korunması ve servis kolaylığı** için uygun kapasitede bir W otomat vardır.
4. Cihaz akülerin **ters kutuplu bağlanması**larına karşı tam korumalıdır.
5. 220V AC girişinde de uygun kapasitede bir W otomat vardır, servis ve bakımda güvenlik ve kolaylık sağlar.
6. Cihazda 'COLD START' özelliği vardır ve START butonuna 2-3 sn süre ile basılıncı, AC nin gelmesi beklenmeden cihaz çalışmaya başlar. Bu özellik ile, elektriğin olmadığı zamanlarda servis ve bakım için cihaz başlatılabilir. Start butonuna paralel bir klemens(START,J701) ile bu özellik uzaktan da kullanılabilir.J701 klemensine sadece **KURU KONTAK** bağlantısı yapılabilir.
7. **KU-S 60VDCX cihaz Akü bağlanmadan da çalışır.** Bu durumda L1 girişindeki AC aynen OUTL çıkışına çıkar. Tabii ki bu durumda bir elektrik kesilmesinde kata getirme işlemi yapılamaz.  
Bu özellik, sahada yeni bir panonun devreye alınmasında ve serviste kolaylık sağlar.
8. **KU-S 60VDCX cihaz bozulsa dahi çıkışı kesilmez, yani L1 girişindeki AC aynen OUTL çıkışına çıkar, asansör kumanda panosu çalışmasına devam eder.**
9. UPS şebeke modunda ise +24- (J7) terminaline 24V DC uygulandığı zaman akü test moduna geçer.Bu özellik ile aküler periyodik olarak test edilebilir.

**Not:** Standart bir UPS yukarıda 7. ve 8.maddedeki özellikleri **sağlayamaz**, yani;

1. Akü yoksa veya zamanla bozulursa **cıkış kesilir**, kumanda panosu **çalışmaz, servis ister**.
2. UPS bozulursa çıkış kesilir, kumanda panosu **çalışmaz, servis ister**.

*Halbuki KU-S 60VDCX ile yukarıdaki her iki durumda da kumanda panosu çalışmasına devam eder, servise gerek yoktur, sadece kurtarma yapılamaz.*

#### **4.CALIŞMA ŞEKLİ:**

1. Başlangıçta L1 fazı yoksa cihaz ölüdür, kontaklar şekilde görüldüğü gibidir.
2. L1 fazı gelince cihaz canlanır, GR ve GRX röleleri çeker, OUTL çıkışı L1'den beslenmeye başlar.
3. L1 fazı kesilince GR rölesi bırakır, Akü bağlıysa, OUTL kesintisiz olarak cihazdan beslenmeye devam eder, çalışma süresi zamanlaması başlar. Çalışma süresi 300 saniyedir.  
*Akü bağlı değilse L1 fazı kesilince OUTL çıkışında kesilir, cihaz ölü duruma geçer. L1 fazı gelince cihaz tekrar canlanır, yukarıdaki 1. Maddeye dönülür.*
4. 20 saniye sonra K1 çeker ve gecikmeli çıkış verilir.
5. 300 saniye dolunca cihaz stop eder ve ölü. Bu andan sonra aküden hiç akım çekilmez, akü daha fazla boşalmaz.

6. L1 fazı gelince cihaz tekrar canlanır, yukarıdaki 1. Maddeye dönülür.

## **5.BUZZER ve LEDLER:**

### **A. Cihaz ŞEBEKEDEN çalışırken:**

1. MAIN, GR, GRX , 15V, 5V ledleri yanar.
2. Akü şarj oluyorsa BAT ledi de yanar, şarj olduktan sonra söner.
3. Aşırı yük oluşursa ve aşırı yük süresince buzzer sürekli öter.

### **B. Şebeke kesilince AKÜDEN çalışırken:**

1. MAIN ve GR ledleri söner, INV ledi (yeşil) yanar, GRX, 15V ve 5V ledleri yanmaya devam eder.
2. Buzzer normal aralıklı olarak ötmeye başlar.  
Aşırı yük oluşursa buzzer sürekli ötmeye başlar.  
Aşırı yük 5 saniyeden az sürerse buzzer tekrar normal aralıklı ötme durumuna döner.  
Aşırı yük uzarsa 5 saniye sonunda cihaz ölü.
3. Normal yük durumunda çalışırken bir süre sonra akü 56.0 Voltun altına inince buzzer daha sık aralıklı olarak ötmeye başlar. 49.0 Volta düşünce de cihaz ölü.

## **6.UYARILAR, TEŞHİS VE GİDERİLMELERİ:**

Problemsiz bir çalışma için akülerin sağlam olması şarttır. Bunu anlamak için;

1. Akülerin herbirinin terminal voltajlarını ayrı ayrı ölçünüz, bunların yaklaşık 12-13 Volt arasında olmaları gereklidir. Bu ölçme sırasında akülerin yüklenmesi yani akülerden bir miktar akım çekilmesi gereklidir. Yük olarak 12V 15-25 Watt arası bir araba far lambası kullanılabilir. Bunun için lamba akünün uçlarına bağlanır ve yanarken bu uçlardaki voltaj ölçülür. Lamba yanarken ısınacağından dikkatli olunmalıdır.
2. Şarj sırasında akülerin terminal voltajlarını ayrı ayrı ölçünüz, çok farklı ve 11 Volttan düşük olanları kullanmayın.
3. Toplam akü geriliği 68-69 Volta kadar çıkışmasına rağmen, ilk yüklemede yani KU-S 60VDCX devreye girince 45V veya daha aşağı düşerse aküleri en az 20 saat şartda tutunuz. Daha sonra aynı olay tekrarlarsa aküleri değiştiriniz.

## **7.PERİYODİK BAKIM:**


1. Genel olarak akülerin verimi ve ömrü ortam sıcaklığına bağlıdır ve en çok 50C dir. Kumanda dolabı içindeki sıcaklığın 50C derece üzerine çıkmaması gereklidir.
2. Akülerin ayda bir kullanılması, yani KU-S 60VDCX cihazın devreye girerek bir kurtarma yapması ve bu sırada akülerden akım çekilmesi faydalıdır. Bunun için her ay yapılan asansör bakımı sırasında, elektriği keserek cihazın devreye girmesini sağlayınız.
3. Cihazı temiz, tozsuz ve rutubetsiz bir ortamda tutunuz.

## **8. GARANTİ:**

SERVOSAN® KURTARAN® KU-S serisi cihazlar, satın alındığı tarihten başlayarak, malzeme, işçilik ve imalat kusurlarına karşı iki yıl garantilidir.

Garanti süresi içerisinde, cihazdaki malzeme, işçilik ve üretim kusurlarından kaynaklanan arızalar bedelsiz olarak giderilecektir. Garanti yalnızca cihazda oluşabilecek arızalar için geçerlidir, bunun dışında herhangi bir hak ya da tazminat istenemez.

## **9.BLOK DİYAGRAM: KU-S /60V DCX-3000VA**



Not: Yukarıdaki şemada görüldüğü gibi gecikmeli çıkış terminalinden, istenirse, kurtarma sırasında aküleri inverterin DC barasına bağlayan kontaktör (Kx) gecikmeli olarak çekirilebilir. Gecikme süresi 20sn dir. UPS şebeke modunda ise +24- (J7) terminaline 24V DC uygulandığı zaman akü test moduna geçer. UPS i elle çalıştırılmak için (Soğuk Başlangıç) START( SV701) butonuna 2-3 sn basılı tutunuz. UPS i uzaktan çalıştırmak için J701 klemensine sadece **KURU KONTAK** bağlantısı yapılmalıdır.



**SERVOSAN®**  
**KURTARAN®**

## **KU-S / 60VDCX – 3000VA**

### **BATTERY POWERED EMERGENCY EVACUATION DEVICE**

### **USER MANUEL**

Publication Date : 11.01.2021  
Program No : 60VDCX\_CA

Number of Pages : 4  
Revision No : 2

	Page
1. List of contents.....	1
2. General.....	1
3. Specifications.....	1
4. Operation .....	2
5. Buzzer and Leds.....	3
6. Warnings, diagnoses and corrections.....	3
7. Periodical maintenance.....	3
8. Warranty.....	4
9. Block Diagram.....	4

#### **2. GENERAL:**

1. This device is mainly a UPS supplied by a **60V** 7AH batteries, with some additional functions.
2. This device can be used for emergency evacuation operation for all elevator panels with inverters of all power ratings, because the inverters DC buses are directly driven from the batteries.
3. The dimensions are, 155mm width, 210mm height, and 228mm depth, weight 13.8 kg.
4. The operating ambient temperature is 0°C - 45°C.

#### **3. SPECIFICATIONS:**

The device has the following additional features in addition to a standard UPS:

1. After the evacuation completed, the device stops after a preselected time, and becomes completely dead and does not consume any current from the batteries. This saves the batteries from discharging during the waiting time for the AC to come back. When AC power comes back, it starts and goes into stand by state.
2. In addition to the main uninterrupted output OUTL, there is a time delayed output **K1(20 sec).**

3. There is a W automat circuit breaker on battery circuit for protection of the batteries and for easy service.
4. The device is fully protected against reverse polarity battery connection.
5. There is a W automat circuit breaker on 220V AC line, for protection and easy service.
6. There is a 'COLD START' function. During the waiting time for the ac power to come back, pushing the start button START(SW701) for 2-3 sec, the device starts without waiting for the L1 phase to come back. This is especially good to make service and maintenance work when ac power is out or is not available.

A remote parallel pushbutton switch connection terminals START (J701) are also available on the pcb. There must be only **DRY CONTACT** connections at START (J701) terminals.

7. **The device functions without battery connection, that means the voltage on L1 input is connected to the OUTL output, even if the batteries are not connected, or discharged completely to zero.**

So the batteries do not cause any additional fault to the operation of the elevator panel. This improves the reliability of the elevator panel equipped with an emergency evacuation device. Of course, in this case, the emergency evacuation operation can not be done.

8. **For most of the possible faults of the device, the L1 and OUTL terminals stays connected, and the elevator panel operates.** So generally the device does not cause any potential fault to the operation of the elevator panel.
9. Applying 24V DC to +27- (J7) Terminals gets the UPS into battery test mode while UPS is in main mode.  
By this function you can test the batteries periodically.

**ATTENTION!** **A standard UPS does not satisfy item 7 and 8 above. A standard UPS with the batteries disconnected, does not start when it is connected to 220V AC for the first start.** That means the 220V AC input voltage stays disconnected from the output terminal, and the elevator panel does not function.

#### **4. OPERATION:**

1. At the beginning, when L1 phase is OFF, the device is dead, and the contacts are as shown in the figure.
2. When L1 phase becomes ON, the device starts operation, the relays GR and GRX become ON, OUTL output is connected to L1 input voltage.
3. When L1 phase fails, GR relay becomes OFF, and if the battery is connected, OUTL continues to supply the load without any interruption, and the operation duration timing starts. Operation duration is 300 seconds.

*If the battery is not connected, when AC fails, the OUTL fails also, and the device dies. When L1 phase comes back, the device starts from the beginning again.*

4. After 20 seconds K1 relay becomes ON, for the delayed output.
5. After 300 seconds, the device stops and becomes completely dead. From now on no current is drawn from the batteries, batteries are saved from discharging.
6. When L1 phase comes back, the device starts operation from the beginning.

## **5.BUZZER and LEDS:**

### **A. When AC power is ON:**

1. MAIN, GR, GRX , 15V, 5V leds are ON.
2. When the battery is charging, the BAT led is ON, when completely charged it becomes OFF. It starts bright and dimmes gradually from the start to the end of the charging.
3. In case of overload, the buzzer beeps continuously.

### **B. When AC is OFF, operation from the batteries:**

1. MAIN and GR leds are OFF, INV led (green), GRX, 15V and 5V leds are ON.
2. Buzzer starts intermittent beeping.  
If overload occurs, buzzer beeps continuously.  
If overload lasts for less than 3 seconds, buzzer starts intermittent beeping again.  
If overload lasts for more than 3 seconds, the device stops and becomes dead.
3. With normal load, when the battery voltage drops below 56.0V, buzzer beeps with higher rate than normal intermittent rate. When the voltage drops below 49.0V, the device stops and dies.

## **6.WARNINGS, DIAGNOSES and CORRECTIONS:**

The batteries must be in good condition for a problem free operation. For this:

1. Measure the terminal voltages of each battery, they sholuld be around 12-13 Volts. During this measurement the batteries must be loaded by a few amperes.
2. Measure the terminal voltages of each battery during charging, do not use the batteries lower than 11.0 Volt terminal voltages after 12 hours.
3. When the total terminal voltage is around 68-69 Volts after the charging, and if it drops below 45 V or lower at the beginning of the first evacuation operation, keep them for charging at least 20 hours. If they drops again below 45 Volt at the beginning of the operation, replace them by new batteries.

## **7.PERIODICAL MAINTENANCE:**


1. For a long service life of the batteries the ambient temperature should be limited to maximum 50 C degree. Since the maximum temperature in the machine room is limited to 45 C degree, this condition may be satisfied.
2. A periodical discharge and charge of the batteries helps to activate the batteries for their maximum use. To do this, let the device make an evacuation operation at least once during the periodical maintenance work of the elevator once in a month.
3. Keep the device in a clean enviroment.

## **8. WARRANTY:**

SERVOSAN KURTARAN KU-S series battery powered emergency evacuation devices are guaranteed for a duration of two years from the date of purchase against breakdowns or faults in parts, components, material and workmanship.

This guarantee by SERVOSAN does not cover the failures or breakdowns due to use of the equipment under abnormal conditions and the damages and breakdowns of components and/or parts that are connected to KURTARAN KU-S series.

## **9. BLOCK DIAGRAM**



Note: The delayed output may be used to connect DC battery terminals to the inverter DC bara (bus) terminals, as shown above. Applying 24V DC to +24- (J7) Terminals gets the UPS into battery test mode while UPS is in main mode. To Start UPS manually(Cold Start Mode), press START(SW701) more than 2-3 seconds. To Start UPS remotely , there must be only **DRY CONTACT** connections at J701 terminals.